EDS / EFS Series Control Stations

DSD Cover and Device Sub-assemblies

For use with EDSCM modular control device bodies see page 519 and EDS/EDSC back boxes.

Features:

- · Large machine screws for fastening covers to bodies
- Lockout hole for padlock having ¼" hasp is provided when used with covers for front lever and side rocker type
- · Lockout provisions on front operated pushbutton (marked "STOP" and "OFF") and all selector switch covers
- For covers with front lever and side rocker type operating handles, threaded type shafts and bushings are used to ensure flametightness
- · Accurately ground flange for flametight joint when mated with ground flange on back box

Certifications and **Compliances:**

(When used with EDSCM & EDS bodies):

• NEC/CEC:

Class I, Division 1 & 2, Groups C, D† Class I, Division 2, Groups B, C, D Class II, Division 1, Groups E, F, G Class II, Division 2, Groups F, G Class III

- NEMA/EEMAC: 3, 7B (Div. 2) CD, 9EFG
- UL Standards: 894, 698
- CSA Standard: C22.2 No. 30

Pushbuttons, Pilot Lights & Selector Switches (when used with EFS bodies):

Class I, Division 1 & 2, Groups B, C, D Class II, Division 1, Groups E, F, G Class II, Division 2, Groups F, G Class III

• NEMA/EEMAC: 3, 7BCD, 9EFG

• UL Standard: 1203

• CSA Standard: C22.2 No. 30

Standard Materials:

- Covers, front operated Feraloy iron alloy and copper-free aluminum
- Covers, side operated copper-free aluminum
- Shafts and shaft bushings stainless steel
- Rocker handles, pushbuttons and guards - type 6 / 6 nylon
- Sealing enclosures copper-free aluminum

CPS delayed action receptacle cover:

- Receptacle housing copper-free aluminum
- Insulation diallyl phthalate (DAP)
- Contacts brass

Cl. I. Div. 1 & 2, Groups B*, C, D† Explosionproof Cl. II, Div. 1, Groups E, F, G Cl. II, Div. 2, Groups F, G CI. III NEMA 3, 7B*CD, 9EFG

Dust-Ignitionproof Raintight Wet Locations

Standard Finishes:

- Feralov electrogalvanized and aluminum acrylic paint
- Copper-free aluminum natural

Options:

The following special options are available by adding suffix to Cat. #:	
	Suffix
Lockout provision on front operated pushbutton cover (standard on buttons marked "STOP" and "OFF")	S153
Three-position selector switches with modified operation:	0.00
Momentary contact clockwise operation, spring return to center, maintained contact counter-clockwise operation	S634
Momentary contact counter-clockwise operation, spring return to center,	3034
maintained contact clockwise operation	S635
 Emergency "STOP" button momentary – front operated mushroom button breaks normally closed contacts (DL02 legend plate included - must specify legend text) 	S111
Bodies and covers – copper-free aluminum	SA
For 24 VDC operation on pilot lights Maintained contact mushroom head with lockout (Will not fit with a pilot light if	S300
transformer is required) (Push to stop only)	S769
Spring return to center from right and left (For DEV43 or DEV44 only)	S842
 Key Operated – removable from all positions	7 K1‡
and DEV44	7 K2±
Key Operated – removable from right position for DEV42 or from left for DEV43	•
and DEV44	7 K3‡ 7 K4±

Ordering Information: **Manual Motor Starters**

Poles	Max. H.P.	Max. Volts A.C.	Cat. #		
With Alle	With Allen-Bradley Bulletin 600 Switches				
1	1	115–230	DSD910 ①		
2	1	115–230	DSD911 ①		
With Gen	With General Electric Switches				
1	1	115–230	DSD912 ①§		
2	1	115–230	DSD913 ⊕§		
With Cutl	With Cutler-Hammer Switches				
1	1	115–230	DSD914 ①§		
2	1	115–230	DSD915 ⊕§		
With Arrow-Hart Switches					
Without Overload Protection					
2	5	250 (30A)	DSD916		
2	7.5	600 (30A)	DSD916		
3	7.5	250 (30A)	DSD917		
3	15	600 (20A)	DSD917		



- † When a CPS receptacle cover device is used, the assembly meets requirements for Class I. Groups C and D areas only.
- For pushbuttons, pilot lights, & selector switches, use EFS back box with required external conduit seal for 1 inch hub size, within 5 feet for Class I, Division 1, Group B applications.
- Additional key lock housings available; please contact Customer Service.
- § A comparable factory sealed cover will fit on the EDSCM21 body, EDS and EDSC bodies and in bottom gang of EDSCM33 and EDSCM63 bodies. To order, add suffix S701 to catalog number.
- ① Includes one interchangeable heater. To select heater see pages 479-480. Symbol 0 (zero) may be used to indicate heater omitted.

EDS / EFS Series Control Stations

DSD Cover and Device Sub-Assemblies

Cl. I. Div. 1 & 2, Groups B*, C, D† Cl. II, Div. 1, Groups E, F, G Cl. II, Div. 2, Groups F, G CI. III NEMA 3, 7B*CD, 9EFG

Explosionproof **Dust-Ignitionproof** Raintight Wet Locations





DSD922









CPS152R



ENR5201

For use with EDSCM modular control device bodies see page 519 & EFS/EDS back boxes.

Ordering Information

Front Operated Pushbutton Stations 600 VAC Heavy Duty, Factory Sealed

Number of Normal			
Cover Buttons		Diagram	Cat. #
1	1 Circuit Universal	• •	DSD918 ①
1	2 Circuits Universal	eie eie	DSD919 ①
	2 Circuits	A B	DSD920 ①■
2	2 Circuits Universal	eie eie	DSD921 ①
2	2 Circuits Start-Stop unless otherwise specified	A B	DSD922 ①■
2	2 Circuits Universal Mushroom Head	ele ele	DSD970 ①
3 (2-operator)	3 Circuits Universal	er ere ere	DSD962 ①
3 (3-operator)	3 Circuits Universal	ere ere ere	DS511 ① SA§
3 (3-operator)	3 Circuits Universal Double pilot light - single pushbutton combo	◎ ◎	DS513 ① SA§
3 (3-operator)	3 Circuits Universal Double pushbutton - single pilot light combo	*** *** (DS514 ① SA§

Front Operated General Use Snap Switch

Style	Amperes 120 VAC	277 VAC	Cat. #
1-Pole	20	20	DSD933‡
2-Pole	20	20	DSD934‡
3-Pole	A	A	DSD935 ©
3-Way	20	20	DSD936‡
4-Way	20	20	DSD937‡
1-Pole	30	30	DSD939‡
2-Pole	30	30	DSD940‡
3-Way	30	30	DSD941‡

Delayed Action Receptacles Factory Sealed

Rating	Cat. #
20 A, 1 HP, 125–250 VAC 60 Hertz	CPS152R
20 A, 18 VDC	(2 wire, 3 pole)
30 A, 1½ HP, 125–250 VAC 60 Hertz;	CPS532R
7 A, ½ HP, 480 VAC, 60 Hertz	(2 wire, 3 pole)
30 A, 3 HP, 125–250 VAC 60 Hertz;	CPS732R
7A, 1 HP, 480 VAC, 60 Hertz	(3 wire, 4 pole)

General Purpose, Dead Front Factory Sealed			
Rating	Cat. #	Diagram	
20 A, 125 VAC	ENR5201		
		5-20R	
20 A, 250 VAC	ENR6202	6-20R	
, ,	on indicating plates ma	ay be added to catalog	

number. Select from the list of standard markings below:

START	OFF	RESET	LIGHT ON
STOP	RUN	TRIP	HAND
ON	JOG	TEST	AUTOMATIC
EMERGENCY	OPEN	DOWN	RAISE
FORWARD	CLOSE	IN	LOWER
REVERSE	UP	OUT	

- * For pushbuttons, pilot lights, & selector switches, use EFS back box with required external conduit seal for 1 inch hub size, within 5 feet for Class I, Division 1, Group B applications. † When a CPS receptacle cover device is used, the assembly meets requirements for Class
- I, Groups C and D areas only.

 Two universal contact blocks, must be wired as two circuits with one normally open and one normally closed. 1 green button, 1 red button, and lockout provision provided as standard.
- ▲16 Amp., 125V.
- 10 Amp., 250V.
- ‡ To order a comparable factory sealed cover for EDS, EDSC, EDSCM21 and the bottom gang of EDSCM33 and EDSCM63 bodies, add suffix S697. Factory sealed for Class I, Division 2, Group B.

 Cannot be factory sealed.

§ Can only be used with EFD Series 1½ gang back boxes. Pushbuttons include contact blocks. Standard pushbutton color is black. For optional colors - red, green - write in color. Example: DS511 GREEN BLACK RED-SA. First color is for uppermost button. For optional legend markings write in marking after device operator color. Example: DS513-J3 JOG-J1 STOP GREEN-SA.