

LIFE SAFETY \mathcal{G} INCIDENT MANAGEMENT

Fire Alarm Stations 270 Series









Overview

EDWARDS 270 Series Non-Coded Fire Alarm Stations are sturdy, attractive, and designed for economical installation.

The station is available in the following operational and functional designs:

- The 270 Series provides a single action, break glass initiating station. It is available with normally open (N.O.), normally closed (N.C.) or combination N.O./N.C. contacts. The basic 270 Series have screw terminals for field connection. The 270A Series Manual Stations have 6 inch (150mm) wire leads.
- The 270P Series is a break glass, normally open pre-signal station. The pull of the lever sounds an alarm on all pre-signal indicating devices. Inserting a key and turning it will initiate a general evacuation alarm. Screw terminals are provided for field connection.

All non-coded stations are designed for either flush or surface mounting. For flush mounting a 4 inch standard North American square box with single gang plaster cover should be used. For surface mounting the 270 Series or 270P Series, use P-027193 Cast Box, P-039250 Steel Box Housing for weatherproof enclosure.

Standard Features

- Pull lever
- Simple positive operation
- Break glass
- Attractive, streamline design
- Less than 5 lb pull force complies with ADA
- Solid, die-cast metal construction



LIFE SAFETY & INCIDENT MANAGEMENT

Contact us


Phone: 800-655-4497 (Option 4)
Email: edwards.fire@carrier.com
Website: edwardsfiresafety.com


8985 Town Center Pkwy Bradenton, FL 34202


© 2020 Carrier All rights reserved.

WARNING: These devices will not operate without electrical power. As fires frequently cause power interruptions, we suggest you discuss further safeguards with your local fire protection specialist.

Mounting







Ordering Information

All models are fire alarm red with Aluminum Strips. They are marked "Pull in Case of Fire" on the pull handle.

| Cat. No. | Marking (top of device) | Switch Contacts | | | Field Connections | | Pre- Signal |
|---------------|-------------------------------|-----------------|----------------|-----------------|--------------------|---------------|----------------|
| | | Single Pole | Double Pole | Open Circuit | Screw Terminals | Wire Leads | Pre- Signal |
| 270-DPO | Fire Alarm | | ✓ | ✓ | ✓ | | |
| 270-DPO- L | Local Alarm | | ✓ | ✓ | ✓ | | |
| 270-SPO | Fire Alarm | ✓ | | ✓ | ✓ | | |
| 270A-DPO | Fire Alarm | | ✓ | ✓ | | ✓ | |
| 270A-SPO | Fire Alarm | ✓ | | ✓ | | ✓ | |
| 270P-DPO | Fire Alarm | | ✓ | ✓ | ✓ | | ✓ |
| 270P-SPO | Fire Alarm | ✓ | | ✓ | ✓ | | ✓ |