120V AC GFCI RECEPTACLE TESTER

61-502 120V AC GFCI RECEPTACLE TESTER

- cULus Certified (UL 1436, CSA C22.2 No. 160) for 120V AC circuits
- · Detects common wiring problems in receptacles
- Confirms operation of GFCI protective devices





Trips GFCI's in circuit by pressing the black button



Test Light will turn on, indicating the activation of the GFCI test and the GFCIs will trip if they are functioning properly


NOTE: Receptacle MUST be properly grounded for the GFCI test to work properly.



Simply plug into outlet and compare which lights are lit to the legend on the tester

LEGEND Indicates a correct wiring condition as wells as the

- following wiring faults:
- open ground reverse polarity
- open hot
- open neutral
- hot and ground reversed
- hot on neutral with hot open



DISCONTINUED

Replaced by 61-502



FEATURES	61-502	61-517	61-051	61-035	61-501
CAT Rating (Safety)	CAT II 150V	CAT II 150V	_	_	_
Listing	UL 1436, CSA C22.2 No. 160	UL 1436, CSA C22.2 No. 160			
Voltage Rating	120V AC	120V AC	120V AC	120V AC	120V AC
Correct/Wiring Fault/Polarity Indications	 ✓ 	 ✓ 	 ✓ 	 Image: A set of the set of the	 ✓
GFCI Trip	 ✓ 	 ✓ 	 ✓ 		 ✓
GFCI Trip Test Indicator	 ✓ 	 ✓ 	_	—	_
Made in the U.S.A.	_	_	 ✓ 	 Image: A start of the start of	_
Neon Lamps	 ✓ 	LED's	 ✓ 	 Image: A set of the set of the	 ✓
LCD Display (Voltage)	_	 ✓ 	_	_	_
Warranty	2-Year*	2-Year*	2-Year*	2-Year*	1-Year*

* Visit www.idealind.com for warranty details.

Specifications are subject to change without notice.

P-6071 (02-23) ©2023 IDEAL INDUSTRIES, INC.

CHAMPION THE ELECTRICIAN'S

IDEAL CUSTOMER SERVICE: orderdesk@idealindustries.com 1-800-824-3325 www.idealind.com