



Accessories



Approvals (according to type):




* Maximum capacity of the jumper link. Each individual pole must not exceed the 6 A limit of the interface to which it is






Approvals (according to type):









Plastic separator

093.01

Thickness 2 mm, required at the start and the end of a group of interfaces.

Can be used for visual separation group, must be used for:

- protective separation of different voltages of neighbouring PLC interfaces according to VDE 0106-101
- protection of cut jumper links



Sheet of marker tags for 38.21/51/61/81/91, plastic, 48 tags, 6 x 10 mm

093.48



Sheet of marker tags (CEMBRE Thermal transfer printers) for 38.01/11/31/41/52/62 types	
(48 tags), 6 x 12 mm	060.48