SIEMENS

Data sheet 5SJ4120-7HG41



Miniature circuit breaker 240 V 14kA, 1-pole, C, 20 A, D=70 mm according to UL 489

SENTRON	
Miniature circuit breakers	
Miniature circuit-breaker 5SJ4	
1	
1P	
C	
10 000	
Suitable for environment B (immunity to interference not applicable)	
F	
3	
3	
440 V	
400 V	
60 V	
50/60 Hz	
240 V	
60 V	
60 V	
125 V	
50 Hz	
IP20, with connected conductors, IP 40 in the handle range	
10 kA	
15 kA	
2.4 W	
240	

suitability for operation	Mechanical engineering / indus	try	
Product details			
product component			
 tunnel terminals top 	No		
 tunnel terminals bottom 	No		
 combined terminal top 	Yes		
 combined terminal bottom 	Yes		
neutral conductor switching	No		
product feature			
halogen-free	Yes		
• sealable	Yes		
• silicon-free	Yes		
product extension installable supplementary devices	Yes		
Product function			
product function note	Terminal tightening torque for C	Cu, 60/75°C; 3.5Nm/31lb.in	
Short circuit			
short-circuit current breaking capacity (Icn) at AC according to UL 1077 and CSA C22.2 No.235	14 kA		
Connections			
connectable conductor cross-section finely stranded with core end processing			
• minimum	0.75 mm ²		
• maximum	25 mm²		
tightening torque with screw-type terminals maximum	3.5 N·m		
position of power supply cord	Any		
Mechanical Design			
height	110 mm		
width	18 mm		
depth	70 mm		
installation depth	70 mm		
number of modular width units	1		
fastening method	on standard mounting rail		
mounting position	any		
net weight	173 g		
Environmental conditions			
standard	IEC / EN 60947-2 / UL 489		
vibration resistance	50 m/s² at 25 to 150Hz and 60m/s² at 35Hz (4sec)		
vibration resistance according to IEC 60068-2-6	±1 mm at 5 to 25 Hz; 50 m/s² at 25 to 150 Hz		
ambient temperature during operation			
• minimum	55 °C		
• maximum	-25 °C		
ambient temperature during operation	max. 95% humidity		
ambient temperature during storage			
• minimum	-40 °C		
• maximum	75 °C		
General Product Approval		Declaration of Conformity	



Confirmation









Test Certificates other Environment

MiscellaneousSpecial Test CertificateConfirmationMiscellaneousEnvironmental Confirmationsatefirmations

urther information

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/lowvoltage/catalogs

Industry Mall (Online ordering system)

 $\underline{https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=5SJ4120-7HG41}$

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

https://support.industry.siemens.com/cs/ww/en/ps/5SJ4120-7HG4

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)


http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=5SJ4120-7HG41


CAx-Online-Generator

http://www.siemens.com/cax

Tender specifications

http://www.siemens.com/specifications





last modified:

8/13/2023