SIEMENS

Data sheet 3SK1122-1CB42



SIRIUS safety relay Basic unit Advanced series with time delay 0.5-30 s electronic enabling circuits 2 NO instantaneous 2 NO delayed Us = 24 V DC screw terminal

| product brand name | SIRIUS |
|--|--|
| product category | Safety relays |
| product designation | safety relays |
| design of the product | Solid-state enabling circuits |
| General technical data | |
| protection class IP of the enclosure | IP20 |
| touch protection against electrical shock | finger-safe |
| insulation voltage rated value | 50 V |
| ambient temperature | |
| during storage | -40 +80 °C |
| during operation | -25 +60 °C |
| air pressure according to SN 31205 | 90 106 kPa |
| relative humidity during operation | 10 95 % |
| installation altitude at height above sea level maximum | 4 000 m; Derating, see Product Notification 109792701 |
| vibration resistance according to IEC 60068-2-6 | 5 500 Hz: 0.75 mm |
| shock resistance | 10g / 11 ms |
| surge voltage resistance rated value | 800 V |
| EMC emitted interference | IEC 60947-5-1, Class A |
| installation environment regarding EMC | This product is suitable for Class A environments only. In household environments, this device can cause unwanted radio interference. The user is required to implement appropriate measures in this case. |
| overvoltage category | 3 |
| degree of pollution | 3 |
| reference code according to IEC 81346-2 | F |
| power loss [W] maximum | 2 W |
| number of sensor inputs 1-channel or 2-channel | 1 |
| design of the cascading | yes |
| type of the safety-related wiring of the inputs | single-channel and two-channel |
| product feature cross-circuit-proof | Yes |
| Safety Integrity Level (SIL) | |
| according to IEC 62061 | 3 |
| according to IEC 61508 | 3 |
| for delayed release circuit according to IEC 61508 | SIL3 |
| performance level (PL) | |
| according to ISO 13849-1 | e |
| • for delayed release circuit according to EN ISO 13849-1 | e |
| category according to EN ISO 13849-1 | 4 |
| Safe failure fraction (SFF) | 99 % |
| PFHD with high demand rate according to EN 62061 | 1.5E-9 1/h |
| PFDavg with low demand rate according to IEC 61508 | 7E-6 |
| T1 value for proof test interval or service life according to | 20 a |

| IEC 61508 | |
|--|------------------------------------|
| hardware fault tolerance according to IEC 61508 | 1 |
| safety device type according to IEC 61508-2 | Type B |
| Inputs/ Outputs | 1) |
| number of outputs as contact-affected switching element | |
| as NO contact | |
| safety-related instantaneous contact | 0 |
| safety-related delayed switching | 0 |
| number of outputs as contact-less semiconductor | |
| switching element | |
| safety-related | |
| — delayed switching | 2 |
| — instantaneous contact | 2 |
| stop category according to EN 60204-1 | 0/1 |
| design of input | |
| cascading input/functional switching | Yes |
| feedback input | Yes |
| • start input | Yes |
| type of electrical connection plug-in socket | No |
| operating frequency maximum | 2 000 1/h |
| switching capacity current | |
| of semiconductor outputs at DC-13 at 24 V | 2 A |
| design of the fuse link for short-circuit protection of the NO | not required |
| contacts of the relay outputs required wire length | |
| | 4 000 m |
| with Cu 1.5 mm² and 150 nF/km per sensor circuit maximum | 4 000 111 |
| make time with automatic start | |
| • at DC maximum | 85 ms |
| make time with automatic start after power failure | |
| • typical | 6 500 ms |
| • maximum | 6 500 ms |
| make time with monitored start | |
| • maximum | 85 ms |
| backslide delay time after opening of the safety circuits | 40 ms |
| typical | |
| adjustable OFF-delay time after opening of the safety circuits | 0.5 30 |
| recovery time after opening of the safety circuits typical | 30 ms |
| recovery time after power failure typical | 6.5 s |
| pulse duration | |
| of the sensor input minimum | 60 ms |
| of the ON pushbutton input minimum | 0.15 s |
| Control circuit/ Control | |
| type of voltage of the control supply voltage | DC |
| control supply voltage | |
| • at DC | |
| — rated value | 24 V |
| operating range factor control supply voltage rated value of | |
| magnet coil | |
| • at DC | 0.8 1.2 |
| Installation/ mounting/ dimensions | |
| mounting position | any |
| required spacing for grounded parts at the side | 5 mm |
| fastening method | screw and snap-on mounting |
| width | 22.5 mm |
| height | 100 mm |
| depth | 121.6 mm |
| Connections/ Terminals | |
| type of electrical connection | screw-type terminals |
| type of connectable conductor cross-sections | |
| • solid | 1x (0.5 2.5 mm²), 2x (1.0 1.5 mm²) |
| | |

| finely stranded | | |
|---|---|--|
| — with core end processing | 1x (0.5 2.5 mm²), 2x (0.5 1.0 mm²) | |
| type of connectable conductor cross-sections for AWG cables | | |
| • solid | 1x (20 14), 2x (18 16) | |
| stranded | 1x (20 16), 2x (20 16) | |
| Product Function | | |
| product function parameterizable | sensor floating / sensor non-floating, monitored start-up / automatic start, 1-channel / 2-channel sensor connection, cross-circuit detection, startup testing, antivalent sensors, 2-hand switches, time delay | |
| suitability for operation device connector 3ZY12 | Yes | |
| suitability for interaction press control | Yes | |
| suitability for use | | |
| safety switch | Yes | |
| monitoring of floating sensors | Yes | |
| monitoring of non-floating sensors | Yes | |
| magnetically operated switch monitoring | Yes | |
| safety-related circuits | Yes | |
| Certificates/ approvals | | |
| | | |



General Product Approval

Confirmation









EMC

Type Examination Certificate





Type Test Certificates/Test Report





| | Marine / Shipping | other | Railway |
|--|-------------------|-------|---------|
|--|-------------------|-------|---------|





Confirmation

Confirmation

Further information

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3SK1122-1CB42

Cax online generator


http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3SK1122-1CB42


 $Service \& Support \ (Manuals, \ Certificates, \ Characteristics, \ FAQs, ...)$


https://support.industry.siemens.com/cs/ww/en/ps/3SK1122-1CB42


Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)

http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3SK1122-1CB42&lang=en









last modified: 8/11/2023 🖸