SIEMENS

Data sheet

7PV1508-1AW30




Timing relay, electronic Multifunction 1 change-over contact, 7 functions 7 time ranges 0.05 s \dots 100 h 12-240 V AC/DC with LED, Screw terminal


product brand name	SIRIUS
product designation	timing relay
design of the product	Multifunctional
product type designation	7PV15
General technical data	
product component semi-conductor output	No
product extension required remote control	No
product extension optional remote control	No
insulation voltage for overvoltage category III according to IEC 60664 with degree of pollution 3 rated value	300 V
test voltage for isolation test	2.2 kV
degree of pollution	2
surge voltage resistance rated value	4 000 V
test voltage for surge voltage test	4 800 V
protection class IP	IP20
shock resistance according to IEC 60068-2-27	11g / 15 ms
vibration resistance according to IEC 60068-2-6	10 55 Hz: 0.35 mm
mechanical service life (operating cycles) typical	10 000 000
electrical endurance (operating cycles) at AC-15 at 230 V typical	100 000
adjustable time	0.05 s 100 h
relative setting accuracy relating to full-scale value	5 %; +/-
minimum ON period	35 ms
recovery time	500 ms
reference code according to IEC 81346-2	К
relative repeat accuracy	2 %; +/-
influence of the surrounding temperature	2% in complete temperature range for the set duration
power supply influence	2% in complete voltage range for the set duration
Substance Prohibitance (Date)	05/01/2012
Control circuit/ Control	
type of voltage of the control supply voltage	AC/DC
control supply voltage 1 at AC	
• at 50 Hz	12 240 V
• at 60 Hz	12 240 V
control supply voltage frequency 1	50 60 Hz
control supply voltage 1	40 04014
• at DC operating range factor control supply voltage rated value at DC	12 240 V
initial value	0.85
full-scale value	1.1
• Iuli-scale value	1.1

operating range factor control supply voltage rated value at	
operating range factor control supply voltage rated value at AC at 50 Hz	
• initial value	0.85
• full-scale value	1.1
operating range factor control supply voltage rated value at	
AC at 60 Hz	
● initial value	0.85
• full-scale value	1.1
Switching Function	
switching function	
ON-delay	Yes
 ON-delay/instantaneous contact 	No
 passing make contact 	Yes
 passing make contact/instantaneous contact 	No
• OFF delay	No
switching function	
 flashing symmetrically with interval start/instantaneous 	No
 flashing symmetrically with interval start 	Yes
flashing symmetrically with pulse start/instantaneous	No
 flashing symmetrically with pulse start 	No
 flashing asymmetrically with interval start 	No
 flashing asymmetrically with pulse start 	No
switching function	
star-delta circuit with delay time	No
star-delta circuit	No
switching function with control signal	
additive ON-delay	Yes
passing break contact	Yes
passing break contact/instantaneous	No
• OFF delay	Yes
OFF delay/instantaneous	No
pulse delayed	No
pulse delayed/instantaneous	No
• pulse-shaping	Yes
• pulse-shaping/instantaneous	No
additive ON-delay/instantaneous	No
ON-delay/OFF-delay	No
ON-delay/OFF-delay/instantaneous	No
passing make contact	No
passing make contact/instantaneous contact	No
switching function of interval relay with control signal	110
retrotriggerable with deactivated control signal/instantaneous contact	No
 retrotriggerable with switched-on control signal 	No
 retrotriggerable with switched-on control signal/instantaneous contact 	No
 retriggerable with deactivated control signal 	No
design of the control terminal non-floating	Yes
Short-circuit protection	
design of the fuse link for short-circuit protection of the auxiliary switch required	fuse gL/gG: 4 A
Auxiliary circuit	
material of switching contacts	AgSnO2
number of NC contacts	
delayed switching	0
instantaneous contact	0
number of NO contacts	
delayed switching	0
instantaneous contact	0
number of CO contacts	
delayed switching	1
instantaneous contact	0
- instantaneous colitact	


operational current of auxiliary contacts at AC-15	
• maximum	3 A
• at 24 V	3 A
• at 250 V	3 A
operational current of auxiliary contacts as NC contact at AC-15	
• at 24 V	3 A
• at 250 V	3 A
operational current of auxiliary contacts as NO contact at	
AC-15	
• at 24 V	3 A
• at 250 V	3 A
operational current of auxiliary contacts at DC-13	1 0.01
operational current of auxiliary contacts at DC-13	
• at 24 V	1 A
• at 125 V	0.22 A
• at 250 V	0.1 A
operating frequency with 3RT2 contactor maximum	5 000 1/h
contact reliability of auxiliary contacts	one incorrect switching operation of 100 million switching operations (17 V, 5
	mA)
contact rating of auxiliary contacts according to ULswitching capacity current with inductive load	R150 / B300 0.01 3 A
	0.01 3 A
Inputs/ Outputs	
product function	
 at the relay outputs switchover delayed/without delay 	No
non-volatile	No
Electromagnetic compatibility	
EMC immunity according to IEC 61812-1	EN 61000-6-2
conducted interference	
 due to burst according to IEC 61000-4-4 	2 kV network connection / 1 kV control connection
 due to conductor-earth surge according to IEC 61000-4-5 	2 kV
due to conductor-conductor surge according to IEC 61000-4-5	1 kV
field-based interference according to IEC 61000-4-3	10 V/m
electrostatic discharge according to IEC 61000-4-2	4 kV contact discharge / 8 kV air discharge
Safety related data	
type of insulation	Basic insulation
category according to EN 954-1	none
Connections/ Terminals	
product component removable terminal for auxiliary and control circuit	No
type of electrical connection for auxiliary and control circuit	screw-type terminals
type of connectable conductor cross-sections	
• solid	1x (0.2 2.5 mm²)
 finely stranded with core end processing 	1x (0.25 1.5 mm ²)
 finely stranded without core end processing 	1x (0.2 1.5 mm²)
for AWG cables solid	1x (24 14)
 for AWG cables stranded 	1x (24 14)
connectable conductor cross-section	
• solid	0.2 2.5 m²
 finely stranded with core end processing 	0.25 1.5 m ²
 finely stranded without core end processing 	0.2 1.5 m ²
AWG number as coded connectable conductor cross section	
• solid	24 14
• stranded	24 14
Installation/ mounting/ dimensions	
mounting position	any
fastening method	snap-on fastening on 35 mm DIN rail
height	90 mm
width	
	17.5 mm
depth	17.5 mm 66.7 mm


equired spacing						
 with side-by-side 	mounting					
- forwards			0 mm			
- backwards			0 mm			
— upwards			0 mm			
- downwards			0 mm			
— at the side			0 mm			
 for grounded part 	S					
— forwards			0 mm			
— backwards			0 mm			
- upwards			0 mm			
at the side			0 mm			
- downwards			0 mm			
 for live parts 						
— forwards			0 mm			
— backwards			0 mm			
			0 mm			
— upwards						
— downwards			0 mm			
— at the side			0 mm			
bient conditions						
	eight above sea level max	ximum	2 000 m			
mbient temperature						
 during operation 			-25 +55 °C			
 during storage 			-40 +70 °C			
 during transport 						
			-40 +70 °C			
elative humidity during	operation		-40 +70 °C 15 85 %			
rtificates/ approvals				۰ ۲	EMC	Declaration of Co formity
elative humidity during rtificates/ approvals General Product Appr CCCC	oval	(U) UL		• •		
rtificates/ approvals General Product Appr CCC	oval	other		[EMC ECM	formity
rtificates/ approvals General Product Approverse CCC Declaration of Con- ormity	oval Confirmation	other Confirmation	15 85 %	nt ntal Con-	EMC ECM	formity
rtificates/ approvals General Product Approverse Contemporation of Con- formity Contemporation Contemporation	oval <u>Confirmation</u> Test Certificates <u>Type Test Certificates</u> <u>Type Test Certificates</u>	Confirmatio	15 85 %	nt ntal Con-	EMC ECM	formity
rtificates/ approvals General Product Appr CCC Declaration of Con- formity CCC Declaration of Con- formity CCC Ther information Siemens has decided https://press.siemens.co Siemens is working or Please contact your loca Siemens is working or Please contact your loca Siemens is working or Please contact your loca AC relevant market (o information - and Down https://www.siemens.co ndustry Mall (Online co	oval <u>Confirmation</u> Test Certificates <u>Type Test Certific-</u> ates/Test Report to exit the Russian mar m/global/en/pressreleas a the renewal of the cur al Siemens office on the s ther than the sanctioned :kaging siemens.com/cs/ww/en/w loadcenter (Catalogs, I m/ic10 ordering system)	Confirmation ket (see here). e/siemens-wind-do rrent EAC certifica status of validity of EAEU member sta iew/109813875 Brochures,)	15 85 %	nt ntal Con- ons	RCM	formity
ther information iemens has decided ttps://press.siemens.co aformation on the par ttps://www.siemens.co aformation- and Down ttps://www.siemens.co aformation- and Down ttps://www.siemens.co	oval Confirmation Test Certificates Type Test Certific- ates/Test Report to exit the Russian mar mm/global/en/pressreleas the renewal of the cur al Siemens office on the s ther than the sanctioned ther than the sanctioned ther than the sanctioned ther than the sanctioned ther in the sanctioned the	Confirmation ket (see here). e/siemens-wind-do rent EAC certifica status of validity of EAEU member status riew/109813875 Brochures,) talog/product?mlfb Korder/default.asp	15 85 %	f you intend to	RCM	formity
rtificates/ approvals General Product Approversion General Product Approversion General Product Approversion General Product Approversion General Product Approversion General Product Approversion Construction of Con- formity Construction of Con- formation of Con- form	oval Confirmation Test Certificates Type Test Certificates Totates/Test Report to exit the Russian mar m/global/en/pressreleas the renewal of the cur al Siemens office on the s ther than the sanctioned taging siemens.com/cs/ww/en/y hloadcenter (Catalogs, I m/ic10 ordering system) nens.com/mall/en/en/Cat n.siemens.com/cs/ww/en/p ut images, 2D dimensi iemens.com/bilddb/cax	Confirmation ket (see here). e/siemens-wind-do rent EAC certifica status of validity of EAEU member stat iew/109813875 Brochures,) talog/product?mlfb Korder/default.aspo racteristics, FAQs bs/7PV1508-1AW3 ion drawings, 3D	15 85 %	f you intend to 	Import or offer to su	formity
rtificates/ approvals General Product Appr CCC Declaration of Con- formity CCC Declaration of Con- formity CCC Declaration of Con- formity CCC Declaration of Con- formity CCC Declaration of Con- formity CCC Con- formity CCC Declaration of Con- formity CCC Declaration of Con- formity CCC Con- formity CCC Declaration of Con- formity CCC Con- formation of Con- formation Siemens has decided https://press.siemens.co Siemens is working of Delase contact your loca CAC relevant market (or nformation on the partition on the part the partition on	oval Confirmation Test Certificates Type Test Certificates Totates/Test Report to exit the Russian mar m/global/en/pressreleas the renewal of the cur al Siemens office on the s ther than the sanctioned taging siemens.com/cs/ww/en/y hloadcenter (Catalogs, I m/ic10 ordering system) nens.com/mall/en/en/Cat n.siemens.com/cs/ww/en/p ut images, 2D dimensi iemens.com/bilddb/cax	Confirmation Ket (see here). e/siemens-wind-do rent EAC certifica status of validity of EAEU member status iew/109813875 Brochures,) talog/product?mlfb Korder/default.aspy racteristics, FAQs is/TPV1508-1AW3 ion drawings, 3D de.aspx?mlfb=7P\	15 85 % Eff Environme m Environmer firmation own-russian-business ates. i the EAC certification is ates Russia or Belarus; =7PV1508-1AW30 (2)ang=en&mlfb=7PV1 s,) 0 models, device circu (1508-1AW30⟨=e	f you intend to 	Import or offer to su	formity






Alle Bemassungswerte sind in Millimeter (mm) angegeben All dimensions are in millimeters (mm)







last modified:

11/21/2022 🖸