## SIEMENS

## Data sheet

## 5SJ4202-7HG42



Circuit breaker 10kA, 2-pole, C, 2A according to UL 489-480Y/277V

Model						
product brand name	SENTRON					
product designation	Miniature circuit breakers					
design of the product	Miniature circuit-breaker 5SJ4					
General technical data						
number of poles	2					
design of pole	2P					
tripping characteristic class	С					
mechanical service life (operating cycles) typical	10 000					
installation environment regarding EMC	Suitable for environment B (immunity to interference not applicable)					
reference code according to DIN 40719 extended according to IEC 204-2 according to IEC 750	F					
overvoltage category	3					
degree of pollution	3					
Voltage						
insulation voltage (Ui) at AC rated value	440 V					
Supply voltage						
supply voltage						
• at AC rated value	400 V					
• at DC rated value	60 V					
value range of the supply voltage frequency	50/60 Hz					
operating voltage						
<ul> <li>at AC according to UL 489 and CSA C22.2 No. 5-02 maximum</li> </ul>	277 V					
<ul> <li>at DC rated value maximum</li> </ul>	60 V					
<ul> <li>at DC single channel according to UL 489 and CSA C22.2 No. 5-02 maximum</li> </ul>	60 V					
<ul> <li>at DC 2-channel according to UL 489 and CSA C22.2 No.</li> <li>5-02 maximum</li> </ul>	125 V					
supply voltage frequency rated value	50 Hz					
Protection class						
protection class IP	IP20, with connected conductors, IP 40 in the handle range					
Switching capacity						
switching capacity current						
<ul> <li>according to EN 60898 rated value</li> </ul>	10 kA					
<ul> <li>according to IEC 60947-2 rated value</li> </ul>	15 kA					
Dissipation						
power loss [W] for rated value of the current at AC in hot operating state per pole	1.8 W					
Main circuit						
type of voltage supply at AC according to UL 489 and CSA C22.2 No. 5-02	480/277					

suitability for operation			Mechanical engineering / i	industry		
Product details						
product component						
<ul> <li>tunnel terminals to</li> </ul>	ор		No			
<ul> <li>tunnel terminals b</li> </ul>	ottom		No			
<ul> <li>combined termina</li> </ul>	al top		Yes			
<ul> <li>combined termina</li> </ul>	al bottom		Yes			
<ul> <li>neutral conductor</li> </ul>	switching		No			
product feature						
<ul> <li>halogen-free</li> </ul>			Yes			
<ul> <li>sealable</li> </ul>			Yes			
<ul> <li>silicon-free</li> </ul>			Yes			
product extension install	lable supplementary devi	Ices	Yes			
Product function						
set values setting currer	nt (li) for I-tripping		7,5			
reference value setting of			x In			
product function note			Terminal tightening torque for Cu, 60/75°C; 3.5Nm/31lb.in			
Short circuit				, ,		
	aking capacity (Icn) at AC 2 No.235	; according to	10 kA			
Connections						
	cross-section finely strand	ded with core				
• minimum			0.75 mm <sup>2</sup>			
maximum			25 mm <sup>2</sup>			
	crew-type terminals maxir	mum	3.5 N·m			
			Any			
Mechanical Design						
height			121 mm			
width			36 mm			
depth			70 mm			
installation depth			70 mm			
number of modular width units		2				
fastening method			on standard mounting rail			
		·				
mounting positionnet weight		any 345 g				
Environmental condition	20		545 g			
				0		
standard		IEC / EN 60947-2 / UL 489 50 m/s <sup>2</sup> at 25 to 150Hz and 60m/s <sup>2</sup> at 35Hz (4sec)				
	ording to IEC 60068 2 6		±1 mm at 5 to 25 Hz; 50 m/s <sup>2</sup> at 25 to 150 Hz			
vibration resistance acco			1 min at 5 to 25 mz, 50 m	1//3 at 20 to 100 HZ		
ambient temperature du	my operation		55 °C			
minimum			55 °C -25 °C			
maximum	ring operation					
ambient temperature du			max. 95% humidity			
ambient temperature du	nng storage		40.80			
• minimum			-40 °C			
maximum			75 °C		Dealerstien (O	
General Product Appr	oval				Declaration of Con- formity	
	<b>Confirmation</b>	$\square$	$\wedge$		~ ~	
(m)		(%)	(D'E)	FAL		
ccc		UL	VDE	LIIL	EG-Konf.	
Declaration of Con-	Test Certificates	other		Environment		



Special Test Certificate **Confirmation** 

Environmental Confirmations

## Further information

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/lowvoltage/catalogs

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=5SJ4202-7HG42

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

https://support.industry.siemens.com/cs/ww/en/ps/5SJ4202-7HG42

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)


http://www.automation.siemens.com/bilddb/cax\_en.aspx?mlfb=5SJ4202-7HG42


CAx-Online-Generator

http://www.siemens.com/cax

**Tender specifications** 

http://www.siemens.com/specifications





last modified:

8/25/2023 🖸