SIEMENS

Data sheet 5SJ4206-7HG41



Miniature circuit breaker 240 V 14kA, 2-pole, C, 6 A, D=70 mm according to UL 489

SENTRON
Miniature circuit breakers
Miniature circuit-breaker 5SJ4
2
2P
С
10 000
Suitable for environment B (immunity to interference not applicable)
F
3
3
440 V
400 V
60 V
50/60 Hz
240 V
60 V
60 V
125 V
50 Hz
IP20, with connected conductors, IP 40 in the handle range
10 kA
15 kA
2.7 W
240

suitability for operation	Mechanical engineering / industry	
Product details		
product component		
• tunnel terminals top	No	
• tunnel terminals bottom	No	
combined terminal top	Yes	
combined terminal bottom	Yes	
neutral conductor switching	No	
product feature		
halogen-free	Yes	
• sealable	Yes	
• silicon-free	Yes	
product extension installable supplementary devices	Yes	
Product function	, 35	
set values setting current (li) for I-tripping	7,5	
reference value setting current (II) for I-tripping	x In	
product function note	Terminal tightening torque for Cu, 60/75°C; 3.5Nm/31lb.i	n
Short circuit	rommar agricoming torquo for our, our roll, continuo fib.i.	
short-circuit current breaking capacity (Icn) at AC according to UL 1077 and CSA C22.2 No.235	14 kA	
Connections		
connectable conductor cross-section finely stranded with core end processing		
• minimum	0.75 mm²	
• maximum	25 mm²	
tightening torque with screw-type terminals maximum	3.5 N·m	
position of power supply cord	Any	
Mechanical Design		
height	110 mm	
width	36 mm	
depth	70 mm	
installation depth	70 mm	
number of modular width units	2	
fastening method	on standard mounting rail	
mounting position	any	
net weight	326 g	
Environmental conditions		
standard	IEC / EN 60947-2 / UL 489	
vibration resistance	50 m/s² at 25 to 150Hz and 60m/s² at 35Hz (4sec)	
vibration resistance according to IEC 60068-2-6	±1 mm at 5 to 25 Hz; 50 m/s² at 25 to 150 Hz	
ambient temperature during operation		
• minimum	55 °C	
• maximum	-25 °C	
ambient temperature during operation	max. 95% humidity	
ambient temperature during storage		
• minimum	-40 °C	
• maximum	75 °C	
General Product Approval		Declaration of Conformity

Confirmation



(F)







Declaration of Conformity Test C	ertificates other	Environment
-----------------------------------	-------------------	-------------



Further information

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/lowvoltage/catalogs

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=5SJ4206-7HG41

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

https://support.industry.siemens.com/cs/ww/en/ps/5SJ4206-7HG4

 $Image\ database\ (product\ images,\ 2D\ dimension\ drawings,\ 3D\ models,\ device\ circuit\ diagrams,\ ...)$


http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=5SJ4206-7HG41


CAx-Online-Generator

http://www.siemens.com/cax

Tender specifications

http://www.siemens.com/specifications





last modified:

8/25/2023

