## SIEMENS

## Data sheet

## 5SJ4211-7HG41



Miniature circuit breaker 240 V 14kA, 2-pole, C, 5A, D=70 mm according to UL 489

Model			
product brand name	SENTRON		
product designation	Miniature circuit breakers		
design of the product	Miniature circuit-breaker 5SJ4		
General technical data			
number of poles	2		
design of pole	2P		
tripping characteristic class	C		
mechanical service life (operating cycles) typical	10 000		
installation environment regarding EMC	Suitable for environment B (immunity to interference not applicable)		
reference code according to DIN 40719 extended according to IEC 204-2 according to IEC 750	F		
overvoltage category	3		
degree of pollution	3		
Voltage			
insulation voltage (Ui) at AC rated value	440 V		
Supply voltage			
supply voltage			
at AC rated value	400 V		
at DC rated value	60 V		
value range of the supply voltage frequency	50/60 Hz		
operating voltage			
<ul> <li>at AC according to UL 489 and CSA C22.2 No. 5-02 maximum</li> </ul>	240 V		
<ul> <li>at DC rated value maximum</li> </ul>	60 V		
<ul> <li>at DC 1-channel according to UL 489 and CSA C22.2 No.</li> <li>5-02 maximum</li> </ul>	60 V		
<ul> <li>at DC 2-channel according to UL 489 and CSA C22.2 No.</li> <li>5-02 maximum</li> </ul>	125 V		
supply voltage frequency rated value	50 Hz		
Protection class			
protection class IP	IP20, with connected conductors, IP 40 in the handle range		
Switching capacity			
switching capacity current			
<ul> <li>according to EN 60898 rated value</li> </ul>	10 kA		
<ul> <li>according to IEC 60947-2 rated value</li> </ul>	15 kA		
Dissipation			
power loss [W] for rated value of the current at AC in hot operating state per pole	2.9 W		
Main circuit			
type of voltage supply at AC according to UL 489 and CSA C22.2 No. 5-02	240		

suitability for operation			Mechanical engineering	g / industry		
Product details						
product component						
<ul> <li>tunnel terminals top</li> </ul>			No			
<ul> <li>tunnel terminals botto</li> </ul>	m		No			
<ul> <li>combined terminal top</li> </ul>	)		Yes			
<ul> <li>combined terminal bo</li> </ul>	ttom		Yes			
<ul> <li>neutral conductor swi</li> </ul>	tching		No			
product feature						
<ul> <li>halogen-free</li> </ul>			Yes			
<ul> <li>sealable</li> </ul>			Yes			
<ul> <li>silicon-free</li> </ul>			Yes			
product extension installable	supplementary dev	ices	Yes			
Product function						
set values setting current (li	for I-tripping		6,5			
reference value setting curre	ent (li) for I-tripping		x In			
product function note			Terminal tightening torque for Cu, 60/75°C; 3.5Nm/31lb.in			
Short circuit						
short-circuit current breaking UL 1077 and CSA C22.2 No		ccording to	14 kA			
Connections						
connectable conductor cross end processing	s-section finely stran	ded with core				
• minimum			0.75 mm <sup>2</sup>			
<ul> <li>maximum</li> </ul>			25 mm <sup>2</sup>			
tightening torque with screw	-type terminals maxi	mum	3.5 N·m			
position of power supply cor			Any			
Mechanical Design						
height			110 mm			
width			36 mm			
depth			70 mm			
installation depth			70 mm			
number of modular width un	its		2			
fastening method			on standard mounting rail			
mounting position		any				
net weight		327 g				
Environmental conditions						
standard		IEC / EN 60947-2 / UL 489				
vibration resistance		50 m/s² at 25 to 150Hz and 60m/s² at 35Hz (4sec)				
vibration resistance according to IEC 60068-2-6		±1 mm at 5 to 25 Hz; 50 m/s² at 25 to 150 Hz				
ambient temperature during	operation					
minimum			55 °C			
<ul> <li>maximum</li> </ul>			-25 °C			
ambient temperature during	operation		max. 95% humidity			
ambient temperature during	storage					
<ul> <li>minimum</li> </ul>			-40 °C			
<ul> <li>maximum</li> </ul>			75 °C			
General Product Approva					Declaration of Con- formity	
~	Confirmation	~	^			
$(\mathbf{m})$	<u></u>	(11)		S FAL	(	
				΄ ΕΠΙ		
ccc		UL	VDE		EG-Konf.	
Declaration of Con-						



Special Test Certificate Confirmation

Environmental Confirmations

## Further information

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/lowvoltage/catalogs

Industry Mall (Online ordering system)

 $\underline{https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=5SJ4211-7HG41}$ 

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

https://support.industry.siemens.com/cs/ww/en/ps/5SJ4211-7HG41

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)


http://www.automation.siemens.com/bilddb/cax\_en.aspx?mlfb=5SJ4211-7HG41


CAx-Online-Generator

http://www.siemens.com/cax

**Tender specifications** 

http://www.siemens.com/specifications





last modified:

8/25/2023 🖸

10/2/2023