## SIEMENS

## Data sheet

## 5SJ4310-7HG41



Miniature circuit breaker 240 V 14kA, 3-pole, C, 10A, D=70 mm according to UL 489  $\,$ 

Model						
product brand name	SENTRON					
product designation	Miniature circuit breakers					
design of the product	Miniature circuit-breaker 5SJ4					
General technical data						
number of poles	3					
design of pole	3P					
tripping characteristic class	C					
mechanical service life (operating cycles) typical	10 000					
installation environment regarding EMC	Suitable for environment B (immunity to interference not applicable)					
reference code according to DIN 40719 extended according to IEC 204-2 according to IEC 750	F					
overvoltage category	3					
degree of pollution	3					
Voltage						
insulation voltage (Ui) at AC rated value	440 V					
Supply voltage						
supply voltage						
<ul> <li>at AC rated value</li> </ul>	400 V					
<ul> <li>at DC rated value</li> </ul>	60 V					
value range of the supply voltage frequency	50/60 Hz					
operating voltage						
<ul> <li>at AC according to UL 489 and CSA C22.2 No. 5-02 maximum</li> </ul>	240 V					
<ul> <li>at DC rated value maximum</li> </ul>	60 V					
<ul> <li>at DC 1-channel according to UL 489 and CSA C22.2 No.</li> <li>5-02 maximum</li> </ul>	60 V					
<ul> <li>at DC 2-channel according to UL 489 and CSA C22.2 No.</li> <li>5-02 maximum</li> </ul>	125 V					
supply voltage frequency rated value	50 Hz					
Protection class						
protection class IP	IP20, with connected conductors, IP 40 in the handle range					
Switching capacity						
switching capacity current						
<ul> <li>according to EN 60898 rated value</li> </ul>	10 kA					
<ul> <li>according to IEC 60947-2 rated value</li> </ul>	15 kA					
Dissipation						
power loss [W] for rated value of the current at AC in hot operating state per pole	1.4 W					
Main circuit						
type of voltage supply at AC according to UL 489 and CSA C22.2 No. 5-02	240					

suitability for operation			Mechanical engineering / industry				
Product details							
product component							
<ul> <li>tunnel terminals t</li> </ul>	top		No				
<ul> <li>tunnel terminals I</li> </ul>	bottom		No				
<ul> <li>combined termination</li> </ul>	al top		Yes				
<ul> <li>combined termination</li> </ul>	al bottom		Yes				
<ul> <li>neutral conductor</li> </ul>	r switching		No				
product feature							
<ul> <li>halogen-free</li> </ul>			Yes				
sealable			Yes				
<ul> <li>silicon-free</li> </ul>			Yes				
product extension insta	llable supplementary devi	ices	Yes				
Product function							
set values setting curre	nt (li) for I-tripping		7,5				
reference value setting			x In				
product function note			Terminal tightening torque for Cu, 60/75°C; 3.5Nm/31lb.in				
Short circuit							
	aking capacity (Icn) at AC .2 No.235	c according to	14 kA				
Connections							
	cross-section finely strand	ded with core					
minimum			0.75 mm²				
maximum			25 mm <sup>2</sup>				
	crew-type terminals maxii	mum	3.5 N·m				
position of power supply			Any				
Mechanical Design			,,				
height			110 mm				
width			54 mm				
			70 mm				
depth							
installation depth number of modular widt	th unito		70 mm				
			3				
			on standard mounting rail				
mounting position			any				
			477 g				
Environmental conditio	ns						
			IEC / EN 60947-2 / UL 489				
vibration resistance			50 m/s <sup>2</sup> at 25 to 150Hz and 60m/s <sup>2</sup> at 35Hz (4sec)				
	cording to IEC 60068-2-6		±1 mm at 5 to 25 Hz; 50 m/s	2 at 25 to 150 Hz			
ambient temperature du	uring operation						
• minimum			55 °C				
• maximum			-25 °C				
ambient temperature du	•		max. 95% humidity				
ambient temperature du	uring storage						
<ul> <li>minimum</li> </ul>			-40 °C				
<ul> <li>maximum</li> </ul>			75 °C				
General Product App	roval				Declaration of Con- formity		
<b>Confirmation</b>							
	(M)	(\U_	(DVE)	EHE	UK CA		
	ccc	UL	VDE				
Declaration of Con-							
formity	Test Certificates	other		Environment			



Special Test Certificate **Confirmation** 

Environmental Confirmations

## Further information

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/lowvoltage/catalogs

Industry Mall (Online ordering system)

 $\underline{https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=5SJ4310-7HG41}$ 

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

https://support.industry.siemens.com/cs/ww/en/ps/5SJ4310-7HG41

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)


http://www.automation.siemens.com/bilddb/cax\_en.aspx?mlfb=5SJ4310-7HG41


CAx-Online-Generator

http://www.siemens.com/cax

**Tender specifications** 

http://www.siemens.com/specifications





last modified:

8/25/2023 🖸

10/11/2023