SIEMENS

Data sheet

3UG4513-1BR20



!!! product phase-out !!! The preferred successor type is 3UG5514-1BR20 phase failure and sequence adjustment undervoltage analog monitoring relay phase failure and sequence adjustable undervoltage asymmetry 20% fixed 3 x 160 to 690 V 50 to 60 Hz AC hysteresis 5% fixed delay time 0-20 s 2 changeover contacts screw terminal

| product brand name | SIRIUS | | | |
|--|--|--|--|--|
| product designation | Network monitoring relay with analog setting | | | |
| design of the product | 4 functions | | | |
| product type designation | 3UG4 | | | |
| General technical data | | | | |
| product function | Phase monitoring relay | | | |
| display version LED | Yes | | | |
| insulation voltage for overvoltage category III according to IEC 60664 | | | | |
| with degree of pollution 3 rated value | 690 V | | | |
| degree of pollution | 3 | | | |
| type of voltage | | | | |
| for monitoring | AC | | | |
| of the control supply voltage | AC | | | |
| surge voltage resistance rated value | 6 kV | | | |
| protection class IP | IP20 | | | |
| shock resistance according to IEC 60068-2-27 | sinusoidal half-wave 15g / 11 ms | | | |
| vibration resistance according to IEC 60068-2-6 | 1 6 Hz: 15 mm, 6 500 Hz: 2g | | | |
| mechanical service life (operating cycles) typical | 10 000 000 | | | |
| electrical endurance (operating cycles) at AC-15 at 230 V typical | 100 000 | | | |
| thermal current of the switching element with contacts maximum | 5 A | | | |
| reference code according to IEC 81346-2 | К | | | |
| relative repeat accuracy | 1 % | | | |
| Substance Prohibitance (Date) | 05/01/2012 | | | |
| SVHC substance name | Blei - 7439-92-1 Bleimonoxid (Bleioxid) - 1317-36-8 | | | |
| Product Function | | | | |
| product function | | | | |
| undervoltage detection | Yes | | | |
| overvoltage detection | No | | | |
| phase sequence recognition | Yes | | | |
| phase failure detection | Yes | | | |
| asymmetry detection | Yes | | | |
| overvoltage detection 3 phase | No | | | |
| undervoltage detection 3 phases | Yes | | | |
| voltage window recognition 3 phase | No | | | |
| adjustable open/closed-circuit current principle | No | | | |
| • auto-RESET | Yes | | | |
| Control circuit/ Control | | | | |

| control supply voltage at AC | |
|---|---|
| • at 50 Hz rated value | 160 690 V |
| • at 60 Hz rated value | 160 690 V |
| operating range factor control supply voltage rated value at AC at 50 Hz | |
| initial value | 1 |
| full-scale value | 1 |
| operating range factor control supply voltage rated value at AC at 60 Hz | |
| initial value | 1 |
| • full-scale value | 1 |
| Measuring circuit | |
| measurable voltage at AC | 160 690 V |
| Precision | |
| relative metering precision | 5 % |
| Auxiliary circuit | |
| number of NC contacts delayed switching | 0 |
| number of NO contacts delayed switching | 0 |
| number of CO contacts | |
| for auxiliary contacts | 2 |
| delayed switching | 2 |
| operating frequency with 3RT2 contactor maximum | 5 000 1/h |
| Main circuit | |
| number of poles for main current circuit | 3 |
| ampacity of the output relay at AC-15 | |
| • at 250 V at 50/60 Hz | 3 A |
| • at 400 V at 50/60 Hz | 3 A |
| ampacity of the output relay at DC-13 | |
| • at 24 V | 1 A |
| • at 125 V | 0.2 A |
| • at 250 V | 0.1 A |
| operational current at 17 V minimum | 5 mA |
| continuous current of the DIAZED fuse link of the output | 4 A |
| relay | |
| Electromagnetic compatibility | |
| conducted interference | 0.174 |
| due to burst according to IEC 61000-4-4 | 2 kV |
| • due to conductor-earth surge according to IEC 61000-4-5 | 2 kV |
| due to conductor-conductor surge according to IEC 61000-4-5 | 1 kV |
| field-based interference according to IEC 61000-4-3 | 10 V/m |
| electrostatic discharge according to IEC 61000-4-2 | 6 kV contact discharge / 8 kV air discharge |
| Galvanic isolation | |
| galvanic isolation | |
| between input and output | Yes |
| between the outputs | Yes |
| between the voltage supply and other circuits | Yes |
| Connections/ Terminals | |
| product component removable terminal for auxiliary and control circuit | Yes |
| type of electrical connection | screw-type terminals |
| type of connectable conductor cross-sections | |
| • solid | 1x (0.5 4.0 mm²), 2x (0.5 2.5 mm²) |
| finely stranded with core end processing | 1x (0.5 2.5 mm²), 2x (0.5 1.5 mm²) |
| for AWG cables solid | 2x (20 14) |
| for AWG cables stranded | 2x (20 14) |
| connectable conductor cross-section | |
| • solid | 0.5 4 mm² |
| finely stranded with core end processing | 0.5 2.5 mm ² |
| AWG number as coded connectable conductor cross section | |
| • solid | 20 14 |

| stranded | | | 20 14 | 1 | | |
|---------------------------------------|-------------------------------|---|--------------------|---------------------------|--------|---------------------|
| tightening torque with so | crew-type terminals | | 0.8 1 | | | |
| Installation/ mounting/ c | | _ | | | | |
| mounting position | | | any | | | |
| fastening method | | | | n mounting | | |
| height | | | 92 mm | | | |
| width | | | 22.5 m | n | | |
| depth | | | 91 mm | | | |
| required spacing | | | | | | |
| with side-by-side | mounting | | | | | |
| — forwards | | | 0 mm | | | |
| — backwards | | | 0 mm | | | |
| — upwards | | | 0 mm | | | |
| — downwards | | | 0 mm | | | |
| — at the side | | | 0 mm | | | |
| for grounded part | S | | | | | |
| - forwards | | | 0 mm | | | |
| — backwards | | | 0 mm | | | |
| — upwards | | | 0 mm | | | |
| — at the side | | | 0 mm | | | |
| — downwards | | | 0 mm | | | |
| for live parts | | | | | | |
| — forwards | | | 0 mm | | | |
| — backwards | | | 0 mm | | | |
| — upwards | | | 0 mm | | | |
| — downwards | | | 0 mm | | | |
| — at the side | | | 0 mm | | | |
| Ambient conditions | | | | | | |
| installation altitude at he | eight above sea level maxii | mum | 2 000 n | n | | |
| ambient temperature | | | | | | |
| during operation | | | -25 + | -60 °C | | |
| during storage | | | -40 + | -85 °C | | |
| during transport | | | -40 + | ∙85 °C | | |
| Certificates/ approvals | | | | | | |
| General Product Appr | oval | | | | EMC | Declaration of Con- |
| | | | | | | formity |
| | <u>Confirmation</u> | UL UL | | EHC | RCM | UK CA |
| Declaration of Con- formity | Test Certificates | | | Marine / Shipping | | other |
| CE EG-Konf. | Special Test Certific- ate | <u>Type Test Certi</u> <u>ates/Test Repc</u> | <u>fic-</u> ort | Lloyds Kegister urs | DIVUGL | <u>Confirmation</u> |
| Railway | | | | | | |
| | | | | | | |

Vibration and Shock

 Further information

 Siemens has decided to exit the Russian market (see here).

 https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

 Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10 Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3UG4513-1BR20

Cax online generator

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3UG4513-1BR20

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)


https://support.industry.siemens.com/cs/ww/en/ps/3UG4513-1BR20

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)

http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3UG4513-1BR20&lang=en

Characteristic: Derating

https://support.industry.siemens.com/cs/ww/en/ps/3UG4513-1BR20/manual



last modified:

8/22/2023 🖸