SIEMENS

Data sheet

6GK1415-2AA10



SIMATIC NET, DP/AS-Interface Link 20 E, Gateway PROFIBUS DP/AS-Interface according to AS-Interface specification V 3.0 in degree of protection IP20

General technical data				
product designation		PROFIBUS DP/AS-Interface Link		
product type designation		DP/AS-Interface Link 20E (AS-i V 3.0)		
protection class IP		IP20		
type of electrical connection of the AS-Interface		Screw-type connection		
type of voltage supply		via AS-i		
consumed current				
 from profile conductors of the AS-Interface 				
— at 30 V maximum	mA	200		
power loss [W]	W	4.5		
insulation voltage rated value	V	500		
product feature redundancy capability		Yes		
• note		in connection with Y-Link		
product function suitable for AS-i Power24V		No		
note		from product status 2 / firmware V3.1		
product function				
 web-based management 		No		
 diagnostics via email 		No		
galvanic isolation		Yes		
display version				
 as status display by LED 		PWR, APF, CER, AUP, CM, BF, SF		
type of configuration of the AS-Interface		Set pushbutton on device, STEP7, GSD, command interface		
Communication/ Protocol				
version of the AS-Interface specification		V 3.0		
AS-Interface master profile is supported		M4 (in acc. with AS-interface specification V 3.0)		
type of data transmission		PROFIBUS		
number of interfaces				
 as AS-Interface 		1		
 according to RS 485 		1		
 according to Industrial Ethernet 		0		
 according to PROFINET 		0		
 according to wireless 		0		
 according to USB 		0		
• other		0		
product component optical interface		No		
protocol is supported				
 ASIsafe (Safety at work) protocol 		No		
 PROFIsafe protocol 		No		
 PROFIBUS protocol 		Yes		
 PROFINET IO protocol 		No		

 PROFINET CBA protocol 		No			
• TCP/IP		No			
• SNMP		No			
standard for wireless communication IEEE 802.11		No			
Inputs/ Outputs					
number of inputs for AS-Interface maximum		496			
number of outputs for AS-Interface maximum		496			
number of AS-i slaves per AS-Interface maximum		62			
bus cycle time of the AS-Interface					
 for 31 slaves 	ms	5			
• for 62 slaves	ms	10			
access to digital I/O data		via process im	age/peripheral addresses	3	
access to analog I/O data		via data record	•••		
Mechanical data					
width	mm	90			
height	mm	80			
		62			
depth fastening method	mm		ning on 35 mm DIN rail		
fastening method		IP20	ing on 55 min Divial		
module format		IF20			
Ambient conditions					
ambient temperature					
• if installed on horizontal mounting rail during operation	°C	0 60			
• if installed on vertical mounting rail during operation	°C	0 45			
 during transport 	°C	-40 +70			
during storage	°C	-40 +70			
relative humidity at 25 °C during operation maximum	%	95			
installation altitude at height above sea level maximum	m	2 000			
Safety related data					
suitability for use safety-related function		No			
explosion protection marking for intrinsic safety of related					
equipment					
• EEx ia		No			
• EEx ib		No			
explosion protection category for gas		II 3 G Ex ec IIC T4 Gc			
explosion protection category for dust		none			
Certificates/ approvals					
General Product Approval			EMC	For use in hazard- ous locations	
Confirmation EM		гпг	A	(For	
ଞ୍ଚ		FHI	<u>(</u>)	Car	
UL			RCM	cqc	
For use in hazard- Declaration of Con-					
ous locations formity					
Oranformatio	_				
Confirmatio	<u>n</u>				
(th) CE					
(t) (€					
(t) (€					
Further information		_			
Further information Siemens has decided to exit the Russian market (see here). https://press.siemens.com/global/en/pressrelease/siemens-wind-do		usiness			
Further information Siemens has decided to exit the Russian market (see here). https://press.siemens.com/global/en/pressrelease/siemens-wind-do Siemens is working on the renewal of the current EAC certification	ates.				
Further information Siemens has decided to exit the Russian market (see here). https://press.siemens.com/global/en/pressrelease/siemens-wind-do Siemens is working on the renewal of the current EAC certifica Please contact your local Siemens office on the status of validity of	tes. the EAC cert	ification if you inter	nd to import or offer to su	oply these products to an	
Further information Siemens has decided to exit the Russian market (see here). https://press.siemens.com/global/en/pressrelease/siemens-wind-do Siemens is working on the renewal of the current EAC certification	tes. the EAC cert	ification if you inter	nd to import or offer to su	oply these products to an	


Information- and Downloadcenter (Catalogs, Brochures,...) https://www.siemens.com/ic10 Industry Mall (Online ordering system)


https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=6GK1415-2AA10 Cax online generator

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=6GK1415-2AA10

Service&Support (Manuals, Certificates, Characteristics, FAQs,...) https://support.industry.siemens.com/cs/ww/en/ps/6GK1415-2AA10

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...) http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=6GK1415-2AA10&lang=en





last modified:

8/11/2023 🖸