SIEMENS

Data sheet

3RB3123-4QB0



Overload relay 6...25 A Electronic For motor protection Size S0, Class 5...30 Contactor mounting Main circuit: Screw Auxiliary circuit: Screw Manual-Automatic-Reset Internal ground fault detection

product brand name	SIRIUS
product designation	solid-state overload relay
product type designation	3RB3
General technical data	
size of overload relay	SO
size of contactor can be combined company-specific	SO
power loss [W] for rated value of the current at AC in hot operating state	1.2 W
• per pole	0.4 W
insulation voltage with degree of pollution 3 at AC rated value	690 V
surge voltage resistance rated value	6 kV
maximum permissible voltage for protective separation in networks with grounded star point	
 between auxiliary and auxiliary circuit 	300 V
 between auxiliary and auxiliary circuit 	300 V
 between main and auxiliary circuit 	600 V
 between main and auxiliary circuit 	690 V
shock resistance	15g / 11 ms
according to IEC 60068-2-27	15g / 11 ms; Signaling contact 97 / 98 in position "Tripped": 9g / 11 ms
vibration resistance	1-6 Hz, 15 mm; 6-500 Hz, 20 m/s ² ; 10 cycles
thermal current	25 A
type of protection according to ATEX directive 2014/34/EU	Ex II (2) G [Ex e] [Ex d] [Ex px] ; Ex II (2) D [Ex t] [Ex p]
certificate of suitability according to ATEX directive 2014/34/EU	PTB 09 ATEX 3001
reference code according to IEC 81346-2	F
Substance Prohibitance (Date)	10/01/2009
SVHC substance name	Blei - 7439-92-1 Bleimonoxid (Bleioxid) - 1317-36-8
Ambient conditions	
installation altitude at height above sea level maximum	2 000 m
ambient temperature	
during operation	-25 +60 °C
during storage	-40 +80 °C
during transport	-40 +80 °C
temperature compensation	-25 +60 °C
relative humidity during operation	10 95 %
Main circuit	
number of poles for main current circuit	3
adjustable current response value current of the current- dependent overload release	6 25 A
operating voltage	
rated value	690 V

 for remote-reset function at DC 	24 V
 for remote-reset function at DC at AC-3e rated value maximum 	24 V 690 V
	50 60 Hz
operating frequency rated value	25 A
operational current rated value	
operational current at AC-3e at 400 V rated value	25 A
operating power	2 11 1/1/
• for 3-phase motors at 400 V at 50 Hz	3 11 kW 4 15 kW
 for AC motors at 500 V at 50 Hz for AC motors at 690 V at 50 Hz 	4 13 KW
Auxiliary circuit	5.5 22 NV
design of the auxiliary switch	integrated
number of NC contacts for auxiliary contacts	1
note	for contactor disconnection
number of NO contacts for auxiliary contacts	1
note	for message "tripped"
number of CO contacts for auxiliary contacts	0
operational current of auxiliary contacts at AC-15	
• at 24 V	4 A
• at 110 V	4 A
• at 120 V	4 A
• at 125 V	4 A
• at 230 V	3 A
operational current of auxiliary contacts at DC-13	
• at 24 V	2 A
• at 60 V	0.55 A
• at 110 V	0.3 A
• at 125 V	0.3 A
• at 220 V	0.11 A
Protective and monitoring functions	
trip class	CLASS 5E, 10E, 20E and 30E adjustable
design of the overload release	electronic
response value current of the grounding protection minimum	0.75 x IMotor
response time of the grounding protection in settled state	1 000 ms
operating range of the grounding protection relating to	
current set value	
• minimum	IMotor > lower current setting value
• maximum	IMotor < upper current setting value x 3.5
UL/CSA ratings	
full-load current (FLA) for 3-phase AC motor	
• at 480 V rated value	25 A
at 600 V rated value	25 A
contact rating of auxiliary contacts according to UL	B600 / R300
Short-circuit protection	
design of the fuse link	
for short-circuit protection of the main circuit	
— with type of coordination 1 required	gG: 125 A, RK5: 100 A
— with type of assignment 2 required	gG: 63 A, J: 100 A
• for short-circuit protection of the auxiliary switch required	fuse gG: 6 A
Installation/ mounting/ dimensions	
mounting position	any
fastening method	Contactor mounting
height	87 mm
width	45 mm
depth Connections/ Terminals	84 mm
	Vac
product component removable terminal for auxiliary and control circuit	Yes
type of electrical connection	
for main current circuit	screw-type terminals
 for auxiliary and control circuit 	screw-type terminals
arrangement of electrical connectors for main current	screw-type terminals Top and bottom

circuit	-
type of connectable conductor cross-sections for main contacts	
solid	2x (1 2.5 mm²), 2x (2.5 10 mm²)
	2x 10 mm ²
stranded	
solid or stranded	1x (1 10 mm ²), 2x (1 10 mm ²)
finely stranded with core end processing	1x (1 6 mm²), 2 x (1 6 mm²), 1x 10 mm²
type of connectable conductor cross-sections	
for auxiliary contacts	
— solid	1x (0.5 4 mm²), 2x (0.5 2.5 mm²)
— solid or stranded	1x (0,5 4 mm²), 2x (0,5 2,5 mm²)
 — finely stranded with core end processing 	1x (0.5 2.5 mm²), 2x (0.5 1.5 mm²)
 for AWG cables for auxiliary contacts 	1x (20 14), 2x (20 14)
tightening torque	
 for main contacts with screw-type terminals 	2 2.5 N·m
 for auxiliary contacts with screw-type terminals 	0.8 1.2 N·m
design of screwdriver shaft	Diameter 5 to 6 mm
size of the screwdriver tip	Pozidriv PZ 2
design of the thread of the connection screw	
 for main contacts 	M4
 of the auxiliary and control contacts 	M3
Safety related data	
protection class IP on the front according to IEC 60529	IP20
touch protection on the front according to IEC 60529	finger-safe, for vertical contact from the front
Communication/ Protocol	
type of voltage supply via input/output link master	No
Electromagnetic compatibility	
conducted interference	
due to burst according to IEC 61000-4-4	2 kV (power ports), 1 kV (signal ports) corresponds to degree of severity 3
due to conductor-earth surge according to IEC 61000-4-5	2 kV (line to earth) corresponds to degree of severity 3
due to conductor-conductor surge according to IEC	1 kV (line to line) corresponds to degree of severity 3
61000-4-5	r kv (inte to inte) corresponds to degree of sevenity 5
 due to high-frequency radiation according to IEC 61000- 4-6 	10 V in frequency range 0.15 to 80 MHz, modulation 80 $\%$ AM with 1 kHz
field-based interference according to IEC 61000-4-3	10 V/m
electrostatic discharge according to IEC 61000-4-2	6 kV contact discharge / 8 kV air discharge
Display	
display version for switching status	Slide switch
Certificates/ approvals	
General Product Approval	EMC
Confirmat	
	· · · · · · · · · · · · · · · · · · ·
For use in hazard- ous locations Declaration of Conformity	Test Certificates Marine / Shipping
	Special Test Certific-
	ate ates/Test Report Lovd's
ATEX EG-Konf.	LRS
Marine / Shipping	other
indine / onipping	ouldi
	Confirmation
)
PRS RINA THYS.	
Further information	

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system) https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3RB3123-4QB0

Cax online generator

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3RB3123-4QB0

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

https://support.industry.siemens.com/cs/ww/en/ps/3RB3123-4QB0


Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)


http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3RB3123-4QB0&lang=en

Characteristic: Tripping characteristics, I2t, Let-through current


https://support.industry.siemens.com/cs/ww/en/ps/3RB3123-4QB0/char


Further characteristics (e.g. electrical endurance, switching frequency) http://www.automation.siemens.com/bilddb/index.aspx?view=Search&mlfb=3RB3123-4QB0&objecttype=14&gridview=view1





10/19/2023





last modified:

9/5/2023 🖸